

CERTIFICATE OF CALIBRATION

RAS-AM-260850127

Certificate No:	RAS-AM-260850127	Date:	27/08/2026
Customer:	AL-MAYAL Company		
Location:	Iraq – Basra		

Equipment Description:	VLF AC HIPOT TEST SET		
Manufacture:	HV HIPOT		
Serial Number:	G0320250104		
Model:	VLF-84		
Range:	0-80 Kv / 10A		
Accuracy:	As Per Manufacture Specification	Status:	Calibrated



Calibration Date:	27/08/2026	Calibration Due:	26/08/2027
--------------------------	------------	-------------------------	------------

Environmental Conditions			
Temperature:	(24± 2) °C	Humidity:	(25 ± 10) % RH

Reference Equipment Details:			
Description	Serial No.	Manufacturer	Certificate No.
Multimeter	274996	Fluke	CH09D1877

Test Results:

No.	Reference Values (kV)	Measured Reading (kV)	Deviation (kV)
.1	10.0	10.0	0.00
.2	20.0	20.1	0.1
.3	40.0	40.2	0.2
.4	80.0	79.7	-0.3
No.	Reference Values (mA)	Measured Reading (mA)	Deviation (mA)
.1	10.0	10.0	0
.2	20.0	19.9	-0.1
.3	30.0	30.2	0.2

End of Test Result

Calibration Engineer Signature:

Ahmed Yahya



Instruments or Device Final Status:

QA/QC Manager O.S.A